

VILLAGE OF TUXEDO PARK
80 LORILLARD ROAD
TUXEDO PARK, NEW YORK 10987

DPW Report
January 17, 2024 to February 20, 2024

DPW

1. Retrieved shipments of road salt
2. Plowed and salted roads on January 19th and 20th and February 13th and 17th
3. Filled in large washout on Tuxedo Road
4. Filled potholes with cold patch
5. Re-adjusted roadside mirror on Summit Road
6. Removed fallen trees on Ledge Lane, East Lake Road and at Sewer Plant
7. Repaired a catch basin on East Lake Road
8. Washed and cleaned trucks
9. Removed the sliding mail slot at the Police Booth
10. Cleaned drains and catch basins
11. Cut back brush along Potucket Road
12. Worked on trucks and plows
13. Removed logs from Elephant Pit at the Racetrack to take measurements for a permanent cover
14. Cleared roads of sticks and debris after heavy winds

Water and Sewer

1. Did various water and sewer mark-outs for Dig Safe NY
2. Oversaw new water main tap for the old Gulf Station
3. Installed a new soda ash chemical line at the Water Plant
4. Continued weekend and holiday Water and Sewer operations
5. Repaired a 1" water service leak on Tower Hill Loop
6. Repaired a 6" water main break on Turtle Point Road
7. Obtained weekly meter readings on Village accounts
8. Checked heat in all buildings
9. Sterling Electric re-attached main electric line at the Mountain Farm Pump Station after a tree fell and ripped the service line from the building
10. Obtained various meter readings requested by Denise Spalthoff
11. Cleared access road to the Potucket Storage Tank after heavy winds
12. Did various water and sewer mark-outs for Dig Safe NY