

VILLAGE OF TUXEDO PARK
80 LORILLARD ROAD
P.O. BOX 31
TUXEDO PARK, NEW YORK 10987

DPW Report

December 16, 2020 – January 19, 2021

Roads

1. Plowed and salted roads on 12/16, 12/17, 1/3 and 1/4
2. Received salt shipments
3. Cleared snow from drains ahead of rain
4. Cleaned up fallen trees on West Lake Drive, West Lake Road, Gow residence
5. Salted icy area after rains
6. Installed nature preserve sign at the Racetrack
7. Pick up trees cut by Nelson Tree Service
8. Chipped brush and limbs after Christmas Eve storm
9. Pick up Christmas trees throughout the Village
10. Cleaned drains and catch basins
11. Widened the entrance to the DPW to accommodate salt deliveries
12. Patched potholes with cold patch
13. Cleaned up leaves on Wee Wah Road and East Lake Stable Road

Water

1. Finished 4th quarter meter readings
2. Repaired 1¼ water line on E Lake Stable Road – Pompan
3. Took weekly meter readings at Village-owned buildings
4. Checked heat in all buildings
5. Prepared and sent monthly report to the Health Dept
6. Filled chemical crocks as needed
7. Performed bi-monthly water sampling
8. Installed new valve box cover on valve box on Tower hill Road
9. Rebuilt low lift (raw water) meter at the Water Plant
10. Replaced 6" filter effluent valve on Filter #1 at the Water Plant

Sewer

1. Had sludge removed from digesters
2. Replaced ¾" air lines in digester #1
3. Cleared sewer blockages at the Police Station, old Radzianko house, Wang, McGrath, Wrenn

Sewer (continued)

4. Performed daily maintenance at Sewer Plant
5. Prepared and sent monthly sewer report to the DEC
6. Greased pumps and equipment at Sewer Plant
7. Performed bi-monthly sampling