

VILLAGE OF TUXEDO PARK
80 LORILLARD ROAD
TUXEDO PARK, NEW YORK 10987

DPW Report
November 16, 2022 to December 19, 2022

Roads

1. Picked up leaves throughout the Village
2. Cleaned leaves off of the small triangles
3. Replaced broken glass in windows at the Police Station
4. Insulated the attic at the Police Station
5. Cleaned Wee Wah Park of leaves
6. Replaced missing hardware on doors at the Police Station
7. Repaired garage door at the Village Office
8. Installed tarp over digester tank at the Sewer Plant
9. Put up Christmas lights at the Main and South Gates
10. Received salt deliveries and transferred into salt shed
11. Cleaned drains and catch basins
12. Serviced plow equipment
13. Plowed and salted roads on December 11, December 12, December 15, December 16

Water and Sewer

1. Repaired a leaking water service line in the East Village
2. Continued with water meter installs
3. Excavated a manhole on West Lake Stable Road and raised to road level
4. Did various utility mark-outs for Dig Safe NY
5. Installed a new light switch at the Mountain Farm Pump Station
6. Installed a new shut off valve on a water service line at 180 East Village Road
7. Began 4th quarter meter readings
8. Napp Electric installed a new PH sensor and a new clearwell level transducer at the Water Plant
9. Removed sludge pump from clarifier at the Sewer Plant that became clogged with leaves. Unclogged pump and reinstalled.
10. Checked the Turtle Point Road Pump Station
11. Continued holiday and weekend operations of the Water and Sewer Plants